


GEOLOGICAL SURVEY NO.

MICHIGAN DEPARTMENT OF PUBLIC HEALTH

WATER WELL AND PUMP RECORD

PART 127 ACT 36B, P.A. 1978

PERMIT NUMBER

1 LOCATION OF WELL		Fraction		Section Number	Town Number	Range Number
County Lapeer	Township Name Attica	SW 1/4 NW 1/4 NW 1/4		15	7 N/2	11 E/W
Distance And Direction From Road Intersection 500' S of Peppermill East side of Lk. Pleasant 259 Lake Pleasant - Attica		3 OWNER OF WELL: Gilbert Schumitsch 6139 Attica Rd. Imlay City				
Street Address & City of Well Location 259 Lake Pleasant - Attica		Address Same As Well Location? ☐ Yes ☒ No				
Locate with "X" in Section Below 		4 WELL DEPTH: (completed) 114 ft. Date of Completion 5/20/89				
Sketch Map: Lk. Pleasant		5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Auger ☐ Jetted ☐				
2 FORMATION DESCRIPTION		6 USE: ☒ Domestic ☐ Type I Public ☐ Type III Public ☐ Irrigation ☐ Type IIa Public ☐ Heat pump ☐ Test Well ☐ Type IIb Public ☐				
THICKNESS OF STRATUM		7 CASING: ☐ Steel ☐ Threaded ☒ Plastic ☐ Welded Diameter 5 in. to 110 ft. depth Height: Above XYV Surface 1 ft. Weight 2.926 lbs./ft. Grouded Drill Hole Diameter 8 in. to 110 ft. depth Drive Shoe ☐ Yes ☒ No				
Clay		8 SCREEN: ☐ Not installed Type stainless Diameter 3" Slot 20 Length 4' Set between 110 ft. and 114 ft. FITTINGS: ☒ K-Packer ☐ Lead Packer ☐ Bremer Check ☐ Blank above screen ft. Other				
Fine sand		9 STATIC WATER LEVEL: 60 ft. below land surface ☐ Flow				
Waterbearing gravel		10 PUMPING LEVEL below land surface 50 ft. after 1 hrs. pumping at 15 G.P.M. ft. after hrs. pumping at G.P.M.				
262-2491087		11 WELL HEAD COMPLETION: ☒ Pitless adapter ☐ 12" above grade ☐ Basement offset ☐ Approved pit				
		12 WELL GROUTED? ☐ No ☒ Yes From 0 to 110 ft. ☐ Neat cement ☒ Bentonite ☐ Other No. of bags of cement Additives				
		13 Nearest source of possible contamination Type septic Distance 70 ft. Direction SE Well disinfected upon completion? ☒ Yes ☐ No				
		14 PUMP: ☐ Not installed ☐ Pump installation Only Manufacturer's name Red Jacket Model number 50CNW1 HP 1/2 Volts 230 Length of Drop Pipe 80 ft. capacity 10 G.P.M. TYPE: ☒ Submersible ☐ Jet PRESSURE TANK: Manufacturer's name Well-X-Trol Model number 202 Capacity 5 Gallons				
15. Remarks, elevation, source of data, etc. John Conklin		16. WATER WELL CONTRACTOR'S CERTIFICATION: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Bellinger Well Drilling 1757 REGISTERED BUSINESS NAME 4020 S. Lapeer Rd. Metamora, MI 48455 Address Signed Philip Bellinger Date 7/14/89 AUTHORIZED REPRESENTATIVE				

D67d

(Rev. 10-80)

LOCAL HEALTH DEPT. COPY

IN ADDITION TO PERMIT #14999

READY for final 4-8-99

APEER COUNTY HEALTH DEPARTMENT

SEWAGE DISPOSAL SYSTEM PERMIT

L N° 24594

PROPERTY ADDRESS 259 Lake Pleasant TOWNSHIP Attica SECTION NUMBER 15

NAME OF OWNER Mary Richey

OWNER'S ADDRESS 655 E. Fifth, Imaly City 48444

NAME OF APPLICANT

UBDIVISION LOT SIZE 66 X 132 LOT/PARCEL NUMBER WELL DEPTH

NUMBER OF BEDROOMS 3 PROPERTY TAX IDENTIFICATION NO. 44-003-162-003-00 MECHANICAL GARBAGE DISPOSAL NO

TYPE OF DWELLING: ☒ HOUSE ☐ OTHER ☐ NEW ☒ EXISTING

SUANCE FINAL INSPECTION INSTALLED BY: WAYNE TOBEY

DATE OF SUANCE April 6, 1999 DATE April 8, 1999

SUED Mitch Caskey, R.S./wr RESULT APPROVED

HEALTH DEPARTMENT APPROVAL OF THE PLAN AND INSTALLATION CANNOT BE CONSIDERED A GUARANTEE OF SUCCESSFUL OPERATION EVALUATED BY: Mitch Caskey

DESIGN CRITERIA

PRIMARY TREATMENT	SEPTIC TANKS	GALLONS	GALLONS
Existing		1250	
SECONDARY TREATMENT	35' X 35'± (1,125 square foot) Solid Bed		

262-2491087

COMMENTS

EX. 1,000 GAL. SIGBUS Comp. Tank
w/ EFFLUENT FILTER

- 35' X 35' SOLID BED - Clean Sand
Placed Below Stone.

SKETCH

